


A

B

C

D



SHEET #	DESCRIPTION
1	COVER SHEET & NOTES
2	CABINET OUTLINE
3	CABINET ARRANGEMENT
4	TABLE A: COMPONENT LIST TABLE B: AC BREAKER RATINGS

Rapid Installation and Operation Information

- Unpack and install the charger per the manual.
- Turn on the ac breaker
- Allow the charger to start and reach the set voltage
- Turn on the dc breaker.

If the factory default settings are acceptable, the charger is ready for service.

To change any settings, consult the “Quick Reference Program Chart” to change voltages settings and time delays.

The charger menu returns to the default display if no buttons are pushed for five (5) minutes.

Specifications

Input Voltage: 120/208/240 V, 60Hz
Input Current: 12/7/6 A
Input Circuit Breaker Standard Interrupt – 15/10/10 A
Optional Interrupt – 15/15/15 A
Input Circuit Breaker Interrupt: Standard – 10 kA
Optional – 22 kA and 42 kA

Output Voltage: 52.8 V, dc
Output Current: 12 A
Output Circuit Breaker: 20 A
Output Circuit Breaker Interrupt: 50 kA

Consult order to determine what options are provided.

ISSUES

ISSUE #	DESCRIPTION	ISS. BY ISS. DATE	APP. BY APP. DATE
4	SEE ECN 20094. UPDATED DRAWINGS WITH UNIPOWER LOGO & VERBIAGE.	WD 2/20/15	DBW 2/23/15
<div>APPROVED</div>			

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON:		APPROVALS	DATE
HOLES	+0.004 -0.002	DRAWN KEL	9/25/12
FRACTIONS	±1/32	CHECKED CJM	9/25/12
DECIMALS (XX)	±0.020	APPROVED MCM	9/25/12
DECIMALS (XXX)	±0.010	APPROVED	
ANGLES	±1/2°		

SQUARE CORNERS AND ANGLES ARE 90° UNLESS OTHERWISE SPECIFIED.

WORKMANSHIP:
PER SPEC ENG032

MATERIAL:

FINISH:





PROPRIETARY INFORMATION
NOT TO BE COPIED, USED, TRANSMITTED, OR DISCLOSED WITHOUT
PRIOR WRITTEN PERMISSION FROM UNIPOWER, LLC.



ARE-S04812
STANDARD DRAWINGS


SIZE B	DOC TYPE / NUMBER PN 102-1090-04812	ISSUE 4
SCALE: N/A	SHEET: 1 OF 4	FILE NAME: PN102-1090-04812_ISS_4

(SHOWN WITH DRIP SHIELD REMOVED)




APPROVED


PROPRIETARY INFORMATION		
NOT TO BE COPIED, USED, TRANSMITTED, OR DISCLOSED WITHOUT PRIOR WRITTEN PERMISSION FROM UNIPOWER, LLC.		
SIZE B	DOC TYPE / NUMBER PN 102-1090-04812	ISSUE 4
SCALE: N/A	SHEET: 2 OF 4	FILE NAME: PN102-1090-04812_ISS_4



FRONT OF CABINET WITH
DOOR OPEN AND BACK PANEL
REMOVED FOR CLARITY



FRONT OF BACK PANEL



APPROVED

PROPRIETARY INFORMATION		
NOT TO BE COPIED, USED, TRANSMITTED, OR DISCLOSED WITHOUT PRIOR WRITTEN PERMISSION FROM UNIPOWER, LLC.		
SIZE B	DOC TYPE / NUMBER PN 102-1090-04812	ISSUE 4
SCALE: N/A	SHEET: 3 OF 4	FILE NAME: PN102-1090-04812_ISS_4

TABLE A

SEQ ID	DESCRIPTION	PART #	RECOMMENDED SPARE PARTS
A1	Power Supply PCB	306.2990.48	X
A2	Control and Display PCB	306.2993.00	X
A3	Interface PCB	306.2991.48	X
A4	Trigger Board	306.2989.00	X
A5	Additional Relay PCB (Opt)	306.2994.00	If option is in unit
C1	Cap, Filter	450.1350.00	
C2	Cap, Filter	450.0860.00	
CB1	Circuit Breaker, Input	SEE TABLE B	
CB2	Circuit Breaker, Output	272.0120.20	
CR1	Blocking Diode (Opt)	JS00485	If option is in unit
D1	Free Wheeling Diode	576.0501.00	X
E1	Lightning Arrestor 120/240V(Opt)	JS00885	If option is in unit
L1	Choke, Main	141.3411.00	
L2	Choke Eliminator (Opt)	141.3401.00	
R1	Shunt (50mV)	JM00247	
R2	Resistor, Preload	685.0046.00	
R3/C3	Surge Protection	307.2724.00	
R4/C4	Surge Protection	307.2724.00	
RM1	SCR/Diode Module	583.0151.40	X
RM2	SCR/Diode Module	583.0151.40	X
S2	Ground Switch	240.4130.00	
T1	Transformer, Power 120/208/240V	143.3403.00	
TB1	Terminal Block	JL00230	
TC1	Thermosensor (Opt)	385.5627.11	If option is in unit
Z1	DC Output MOVs (Opt)	JA02986-150V	If option is in unit

TABLE B

Nominal Input Voltage	Interrupt Rating		
	10K	22K	42K
120V	272.0119.15	272.0121.15	272.0123.15
208V	272.0119.10	272.0121.15	272.0123.15
240V	272.0119.10	272.0121.15	272.0123.15

APPROVED

PROPRIETARY INFORMATION		
NOT TO BE COPIED, USED, TRANSMITTED, OR DISCLOSED WITHOUT PRIOR WRITTEN PERMISSION FROM UNIPOWER, LLC.		
SIZE B	DOC TYPE / NUMBER PN 102-1090-04812	ISSUE 4
SCALE: N/A	SHEET: 4 OF 4	FILE NAME: PN102-1090-04812_ISS_4